

**Part III Form 2
Section 11. ANNUAL REPORT.**

| | |
|--|--------------------------------------|
| Drinking-Water System Number: | 220002654 |
| Drinking-Water System Name: | Mildmay Water System |
| Drinking-Water System Owner: | Municipality of South Bruce |
| Drinking-Water System Category: | Large Municipal Residential |
| Period being reported: | January 1, 2025 to December 31, 2025 |

| | |
|---|---|
| <p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a website on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>Municipality of South Bruce Administration Office 21 Gordon Street East Teeswater, Ontario</p> </div> | <p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p> |
|---|---|

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

| Drinking Water System Name | Drinking Water System Number |
|----------------------------|------------------------------|
| N/A | |

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [x] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web**
- Public access/notice via Government Office**
- Public access/notice via a newspaper**
- Public access/notice via Public Request**
- Public access/notice via a Public Library**
- Public access/notice via other method**

Describe your Drinking-Water System

The Mildmay Water System has 2 production wells. Well #1 was drilled in 1968 to a depth of 35 metres. In 1989 a second well was added. This newer well is 250 mm in diameter and 34 metres deep. It is known as Well #2. Each well is capable of pumping 1137 L/min (250 Igpm). The pump house contains Well #1 plus the appropriate appurtenances to disinfect the water and direct it into the distribution system and elevated Storage structure. The pump house also houses a diesel generator set, 2 hypochlorite solution metering pumps, a chemical storage tank, water meters, a chlorine contact simulator, a continuous chlorine analyzer, and a continuous turbidity analyzer. In 2017 a Supervisory Control and Data Acquisition (SCADA) system was installed to monitor chlorine, flow, pressure, and tower level giving the operators 24 hour trending.

Chlorine is introduced into the raw water in the pump house to provide disinfection. The water then passes through a 181 metres length of large diameter piping (with no service connections) where 15 minutes of “contact time” is provided to complete the disinfection process. Residual chlorine levels are maintained within the distribution system to effectively provide disinfection throughout the entire system.

A chlorine contact simulator that provides 15 minutes of contact time before the water reaches the chlorine residual and turbidity analyzers is installed in the pump house.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

N/A

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|---------------|-----------|--------|-----------------|-------------------|------------------------|
| NA | | | | | |

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| | # of E.Coli & Total Coliform Samples | Range of E.Coli or Fecal Results | Range of Total Coliform Results (#-#) | # of HPC Samples | Range of HPC Results (#-#) |
|-----------------------------|--------------------------------------|----------------------------------|---------------------------------------|------------------|----------------------------|
| Well #1 | 52 | 0-0 | 0-0 | | |
| Well #2 | 52 | 0-0 | 0-0 | | |
| Treated (Contact Simulator) | 52 | 0-0 | 0-0 | 52 | <10 - 20 |
| Distribution System | 155 | 0-0 | 0-0 | 104 | <10 - 30 |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Raw Well #1 | | Raw Well #2 | | Treated (Contact Simulator) | | Distribution System | |
|---------------|----------------|------------------------|----------------|------------------------|-----------------------------|------------------------|---------------------|------------------------|
| | # grab samples | Range of Results (#-#) | # grab samples | Range of Results (#-#) | # grab samples | Range of Results (#-#) | # grab samples | Range of Results (#-#) |
| Turbidity | 53 | 0.07-0.33 ntu | 53 | 0.09-0.28 ntu | 53 | 0.06-0.25 ntu | 167 | 0.07-3.36 ntu |
| Free Chlorine | N/A | N/A | N/A | N/A | 366 | 0.88-2.44 | 438 | 0.53-1.96 |

NOTE: Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

| Date of legal instrument issued | Parameter | Date Sampled | Result | Unit of Measure |
|---------------------------------|-----------|--------------|--------|-----------------|
| N/A | | | | |

Summary of Inorganic parameters tested during this reporting period or the most recent sample results (Well #1)

| PARAMETER | SAMPLE DATE | RESULT VALUE | UNIT OF MEASURE | EXCEEDANCE |
|-----------------------------------|--------------------------|--------------|-----------------|------------|
| Alkalinity | Jan. 21, 2025 | 312 | mg/L | No |
| Antimony | Jan. 23, 2024 | <0.6 | ug/L | No |
| Arsenic | Jan. 23, 2024 | <0.2 | ug/L | No |
| Barium | Jan. 23, 2024 | 55.7 | ug/L | No |
| Boron | Jan. 23, 2024 | 13 | ug/L | No |
| Cadmium | Jan. 23, 2024 | 0.003 | ug/L | No |
| Chromium | Jan. 23, 2024 | 0.24 | ug/L | No |
| Lead (Distribution) | Jan. 21, 2025 | 0.21 | ug/L | No |
| Lead 15.1 | Jan. 10, 2023 | 0.24 | ug/L | No |
| | July 25, 2023 | 0.32 | | |
| Mercury | Jan. 23, 2024 | <0.01 | ug/L | No |
| Selenium | Jan. 23, 2024 | 0.28 | ug/L | No |
| Sodium every 5 years next 2026 | Jan. 12, 2021 Well #1 | 10.3 | mg/L | No |
| Uranium | Jan. 23, 2024 | 1.20 | ug/L | No |
| Fluoride every 5 years next 2026) | Jan. 12, 2021 | <0.1 | mg/L | No |
| Nitrate | Jan. 21, 2025 | 4.20 | mg/L | No |
| | Apr. 15, 2025 | 4.20 | mg/L | No |
| | Jul. 16, 2025 | 4.15 | mg/L | No |
| | Oct. 14, 2025 | 4.20 | mg/L | No |
| Nitrite | Jan. 21, 2025 | <0.003 | mg/L | No |
| | Apr. 15, 2025 | <0.003 | mg/L | No |
| | Jul. 16, 2025 | <0.003 | mg/L | No |
| | Oct. 14, 2025 | <0.003 | mg/L | No |

Summary of Organic parameters sampled during this reporting period or the most recent sample results (Well #1)

| Parameter | Sample Date | Results Value | Unit of Measure | Exceedance |
|--------------------------------------|---------------|---------------|-----------------|------------|
| Alachlor | Jan. 23, 2024 | <0.02 | ug/L | No |
| Atrazine + N-dealkylated metabolites | Jan. 23, 2024 | <0.01 | ug/L | No |
| Azinphos-methyl | Jan. 23, 2024 | <0.05 | ug/L | No |
| Benzene | Jan. 23, 2024 | <0.32 | ug/L | No |
| Benzo(a)pyrene | Jan. 23, 2024 | <0.004 | ug/L | No |
| Bromoxynil | Jan. 23, 2024 | <0.33 | ug/L | No |
| Carbaryl | Jan. 23, 2024 | <0.05 | ug/L | No |
| Carbofuran | Jan. 23, 2024 | <0.01 | ug/L | No |
| Carbon Tetrachloride | Jan. 23, 2024 | <0.17 | ug/L | No |
| Chlorpyrifos | Jan. 23, 2024 | <0.02 | ug/L | No |
| Diazinon | Jan. 23, 2024 | <0.02 | ug/L | No |
| Dicamba | Jan. 23, 2024 | <0.20 | ug/L | No |
| 1,2-Dichlorobenzene | Jan. 23, 2024 | <0.41 | ug/L | No |

| | | | | |
|---|--|----------------------------------|------|----|
| 1,4-Dichlorobenzene | Jan. 23, 2024 | <0.36 | ug/L | No |
| 1,2-Dichloroethane | Jan. 23, 2024 | <0.19 | ug/L | No |
| 1,1-Dichloroethene (vinylidene chloride) | Jan. 23, 2024 | <0.41 | ug/L | No |
| Dichloromethane | Jan. 23, 2024 | <0.33 | ug/L | No |
| 2-4 Dichlorophenol | Jan. 23, 2024 | <0.35 | ug/L | No |
| 2,4-D (2,4-Dichlorophenoxy acetic acid) | Jan. 23, 2024 | <0.19 | ug/L | No |
| Diclofop-methyl | Jan. 23, 2024 | <0.40 | ug/L | No |
| Dimethoate | Jan. 23, 2024 | <0.06 | ug/L | No |
| Diquat | Jan. 23, 2024 | <1.0 | ug/L | No |
| Diuron | Jan. 23, 2024 | <0.03 | ug/L | No |
| Glyphosate | Jan. 23, 2024 | <1.0 | ug/L | No |
| HAA (Haloacetic Acid) | Jan. 21, 2025 Apr. 15, 2025 Jul. 16, 2025 Oct. 14, 2025 | <5.30 <5.30 <5.30 <5.30 | ug/L | No |
| Malathion | Jan. 19, 2021 | <0.02 | ug/L | No |
| MCPA (2-Methyl-4-chlorophenoxyacetic acid) | Jan. 23, 2024 | <0.0001 2 | ug/L | No |
| Metolachlor | Jan. 23, 2024 | <0.01 | ug/L | No |
| Metribuzin | Jan. 23, 2024 | <0.02 | ug/L | No |
| Monochlorobenzene | Jan. 23, 2024 | <0.3 | ug/L | No |
| Paraquat | Jan. 23, 2024 | <1.0 | ug/L | No |
| Pentachlorophenol | Jan. 23, 2024 | <0.15 | ug/L | No |
| Phorate | Jan. 23, 2024 | <0.01 | ug/L | No |
| Picloram | Jan. 23, 2024 | <1.0 | ug/L | No |
| Polychlorinated Biphenyls (PCB) | Jan. 23, 2024 | <0.04 | ug/L | No |
| Prometryne | Jan. 23, 2024 | <0.03 | ug/L | No |
| Simazine | Jan. 23, 2024 | <0.01 | ug/L | No |
| THM (Note: show latest annual average) | 2025 Average | 6.7 | ug/L | No |
| Terbufos | Jan. 23, 2024 | <0.01 | ug/L | No |
| Tetrachloroethylene | Jan. 23, 2024 | <0.35 | ug/L | No |
| 2,3,4,6-Tetrachlorophenol | Jan. 23, 2024 | <0.20 | ug/L | No |
| Triallate | Jan. 23, 2024 | <0.01 | ug/L | No |
| Trichloroethylene | Jan. 23, 2024 | <0.44 | ug/L | No |
| 2,4,6-Trichlorophenol | Jan. 23, 2024 | <0.25 | ug/L | No |
| Trifluralin | Jan. 23, 2024 | <0.02 | ug/L | No |
| Vinyl Chloride | Jan. 23, 2024 | <0.17 | ug/L | No |

Summary of Inorganic parameters tested during this reporting period or the most recent sample results (Well #2)

| PARAMETER | SAMPLE DATE | RESULT VALUE | UNIT OF MEASURE | EXCEEDANCE |
|------------------------------------|---------------|--------------|-----------------|------------|
| Alkalinity | Jan. 21, 2025 | 312 | mg/L | No |
| Antimony | Jan. 23, 2024 | <0.6 | ug/L | No |
| Arsenic | Jan. 23, 2024 | <0.2 | ug/L | No |
| Barium | Jan. 23, 2024 | 56.5 | ug/L | No |
| Boron | Jan. 23, 2024 | 14 | ug/L | No |
| Cadmium | Jan. 23, 2024 | 0.005 | ug/L | No |
| Chromium | Jan. 23, 2024 | 0.21 | ug/L | No |
| Lead 15.1 | Mar. 17, 2020 | <1.0 | ug/L | No |
| | | <1.0 | | |
| | Sep. 22, 2020 | <1.0 | | |
| | | 2.2 | | |
| Lead (Distribution) | Jan. 21, 2025 | 0.21 | ug/L | No |
| Mercury | Jan. 23, 2024 | <0.01 | ug/L | No |
| Selenium | Jan. 23, 2024 | 0.25 | ug/L | No |
| Sodium Next 2026 | Jan. 12, 2021 | 10.5 | mg/L | No |
| Uranium | Jan. 23, 2024 | 1.17 | ug/L | No |
| Fluoride (every 5 years next 2026) | Jan. 12, 2021 | <0.1 | mg/L | No |
| Nitrate | Jan. 21, 2025 | 4.18 | mg/L | No |
| | Apr. 15, 2025 | 4.03 | mg/L | No |
| | Jul. 16, 2025 | 4.11 | mg/L | No |
| | Oct. 14, 2025 | 4.20 | mg/L | No |
| Nitrite | Jan. 23, 2024 | <0.003 | mg/L | No |
| | Apr. 09, 2024 | <0.003 | mg/L | No |
| | Jul. 09, 2024 | <0.003 | mg/L | No |
| | Oct. 08, 2024 | <0.003 | mg/L | No |

Summary of Organic parameters sampled during this reporting period or the most recent sample results (Well #2)

| Parameter | Sample Date | Results Value | Unit of Measure | Exceedance |
|--------------------------------------|---------------|---------------|-----------------|------------|
| Alachlor | Jan. 23, 2024 | <0.02 | ug/L | No |
| Atrazine + N-dealkylated metabolites | Jan. 23, 2024 | <0.01 | ug/L | No |
| Azinphos-methyl | Jan. 23, 2024 | <0.05 | ug/L | No |
| Benzene | Jan. 23, 2024 | <0.32 | ug/L | No |
| Benzo(a)pyrene | Jan. 23, 2024 | <0.004 | ug/L | No |
| Bromoxynil | Jan. 23, 2024 | <0.33 | ug/L | No |
| Carbaryl | Jan. 23, 2024 | <0.05 | ug/L | No |
| Carbofuran | Jan. 23, 2024 | <0.01 | ug/L | No |
| Carbon Tetrachloride | Jan. 23, 2024 | <0.17 | ug/L | No |
| Chlorpyrifos | Jan. 23, 2024 | <0.02 | ug/L | No |
| Diazinon | Jan. 23, 2024 | <0.02 | ug/L | No |

| | | | | |
|--|--|----------------------------------|------|----|
| Dicamba | Jan. 23, 2024 | <0.20 | ug/L | No |
| 1,2-Dichlorobenzene | Jan. 23, 2024 | <0.41 | ug/L | No |
| 1,4-Dichlorobenzene | Jan. 23, 2024 | <0.36 | ug/L | No |
| 1,2-Dichloroethane | Jan. 23, 2024 | <0.19 | ug/L | No |
| 1,1-Dichloroethene (vinylidene chloride) | Jan. 23, 2024 | <0.41 | ug/L | No |
| Dichloromethane | Jan. 23, 2024 | <0.33 | ug/L | No |
| 2-4 Dichlorophenol | Jan. 23, 2024 | <0.35 | ug/L | No |
| 2,4-D (2,4-Dichlorophenoxy acetic acid) | Jan. 23, 2024 | <0.19 | ug/L | No |
| Diclofop-methyl | Jan. 23, 2024 | <0.40 | ug/L | No |
| Dimethoate | Jan. 23, 2024 | <0.06 | ug/L | No |
| Diquat | Jan. 23, 2024 | <1.0 | ug/L | No |
| Diuron | Jan. 23, 2024 | <0.03 | ug/L | No |
| Glyphosate | Jan. 23, 2024 | <1.0 | ug/L | No |
| HAA (Haloacetic Acid) | Jan. 21, 2025 Apr. 15, 2025 Jul. 16, 2025 Oct. 14, 2025 | <5.30 <5.30 <5.30 <5.30 | ug/L | No |
| Malathion | Jan. 23, 2024 | <0.01 | ug/L | No |
| MCPA (2-Methyl-4-chlorophenoxyacetic acid) | Jan. 23, 2024 | <0.02 | ug/L | No |
| Metolachlor | Jan. 23, 2024 | <0.3 | ug/L | No |
| Metribuzin | Jan. 23, 2024 | <1.0 | ug/L | No |
| Monochlorobenzene | Jan. 23, 2024 | <0.15 | ug/L | No |
| Paraquat | Jan. 23, 2024 | <0.01 | ug/L | No |
| Pentachlorophenol | Jan. 23, 2024 | <1.0 | ug/L | No |
| Phorate | Jan. 23, 2024 | <0.04 | ug/L | No |
| Picloram | Jan. 23, 2024 | <0.03 | ug/L | No |
| Polychlorinated Biphenyls (PCB) | Jan. 23, 2024 | <0.01 | ug/L | No |
| Prometryne | Jan. 23, 2024 | <0.01 | ug/L | No |
| Simazine | Jan. 23, 2024 | <0.02 | ug/L | No |
| THM (Note: show latest annual average) | 2025 Average | 6.7 | ug/L | No |
| Terbufos | Jan. 23, 2024 | <0.01 | ug/L | No |
| Tetrachloroethylene | Jan. 23, 2024 | <0.35 | ug/L | No |
| 2,3,4,6-Tetrachlorophenol | Jan. 23, 2024 | <0.20 | ug/L | No |
| Triallate | Jan. 23, 2024 | <0.01 | ug/L | No |
| Trichloroethylene | Jan. 23, 2024 | <0.44 | ug/L | No |
| 2,4,6-Trichlorophenol | Jan. 23, 2024 | <0.25 | ug/L | No |
| Trifluralin | Jan. 23, 2024 | <0.02 | ug/L | No |
| Vinyl Chloride | Jan. 23, 2024 | <0.17 | ug/L | No |

*N.D. = Not Detected

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

| Parameter | Result Value | Unit of Measure | Date of Sample |
|----------------|--------------|-----------------|------------------|
| Sodium Well #1 | 10.3 | mg/l | January 12, 2021 |
| Sodium Well #2 | 10.5 | mg/l | January 12, 2021 |